progress of the calculations. It may be enlarged, if necessary, by a heat transfer theory which is accepted today as progressive.

Schuster, H. and Stebel, H.

Large-scale trials of a furnace with low NO_x-emission for coal-fired steam generators with liquid ash removal

Brennst.-Wärme-Kraft, vol. 33, no. 11, pp. 443-446, 1981.

This contribution presents the concept of a slag tap furnace with low NO_x-emission, which has been on trial on a power station block of 150 MW. An extensive test program investigated a number of influencing parameters, and proved that the NO_x-emission can be considerably reduced without detrimentally affecting the operational behavior.

Wenz, W.

Operational results of a novel pulverized coal furnace

Brennst.-Wärme-Kraft, vol. 33, no. 11, pp. 447-450, 1981.

In this article, a novel pulverized coal furnace is described which can replace oil or gas fired boiler plants in the central heating range. The fuel used (called "Fluicit") consists of a mixture of brown coal and anthracite. The fuel, its production and the heating plant are described, as well as the results of tests on combustion, storage and transport. The behavior of the fuel "Fluicit" is also considered with respect to SO_2 and NO_x emissions.

Weissenbach, B., and Clausen, J. J.

Thermal storage power station for peak-load generation near consumers

Brennst.-Wärme-Kraft, vol. 33, no. 12, pp. 479-482, 1981.

The thermal storage power station is potentially useful for storing electrical energy in the form of heat. When required, the heat can be transformed into peak-load electricity. The authors describe the principle of this new storage system, the efficiencies obtainable, the exergy flows, and the technical construction of such a plant. In concluding, conventional plants for peak-load supply are compared to the thermal storage power station.

Fiala, W.

Exergetic analysis of various heat accumulators at changing ambient temperatures

Brennst.-Wärme-Kraft, vol. 33, no. 12, pp. 482-486, 1981.

The article includes exergetic analyses of sensible and latent heat accumulators. The results of these analyses may be of special interest if the accumulator temperature lies within the fluctuation range of a periodically changing ambient temperature. By choosing a suitable storage medium, the total exergy requirement for both heating and cooling can be reduced by the addition—with the correct preceding sign—of the released heat (useful heat) and the absorbed heat (useful cold), provided that there are both heating and cooling requirements within one period of ambient temperature fluctuations.

Alefeld, G.

The heat pump transformator, a device for the utilization of "cold district heat"

Brennst.-Wärme-Kraft, vol. 33, no. 12, pp. 486-490, 1981.

The article describes a device which, supplemented to heat pump operation, can be used as a heat transformer, or perform both processes simultaneously. The temperature of the useful heat and its output can be continuously adjusted to the requirement of the consumer. This device thus opens up great opportunities for the utilization of "cold district heat," which is available, for instance, from waste heat of power stations or industrial plants, or in the return piping of district heating nets. As the demand on primary driving energy for this device initially drops at a reducing outside temperature, especially at night, energy savings can be obtained that are far beyond those that can be reached with ordinary heat pumps. The principle of the heat pump transformer and its possible applications are described.

Cumulative Index to Authors

Al-Arabi, M., vol. 3, nos. 3-4, p. 76
Alkidas, A. C., vol. 3, nos. 3-4, p. 66
Baker, C. K., vol. 1, no. 2, p. 28
Bell, K. J., vol. 2, nos. 3-4, p. 27
Berg, J. L., vol. 1, no. 4, p. 21
Berg, W. F., vol. 1, no. 4, p. 21
Boyer, R. C., vol. 2, no. 1, p. 19
Breber, G., vol. 1, no. 2, p. 47
Butterworth, D., vol. 3, nos. 3-4, p. 104
Carnavos, T. C., vol. 1, no. 2, p. 41; vol. 1, no. 4, p. 32
Charaklis, W. G., vol. 3, no. 1, p. 23
Chenoweth, J. M., vol. 2, no. 2, p. 28
Cocks, A. M., vol. 1, no. 1, p. 31
Collier, J. G., vol. 1, no. 3, p. 56
Cooper, A., vol. 1, no. 1, p. 31; vol. 1, no. 3, p. 50
Cozzuol, J. M., vol. 3, no. 2, p. 31
Cuti, F., vol. 3, no. 1, p. 38
Davies, L. M., vol. 1, no. 3, p. 56
Desmond, R. M., vol. 2, no. 1, p. 59
Everly, D., vol. 3, nos. 3-4, p. 60
Gaddis, E. S., vol. 1, no. 1, p. 43
Genetti, W. E., vol. 3, nos. 3-4, p. 60
Gianolio, E., vol. 3, no. 1, p. 38
Graham, R. W., vol. 2, no. 1, p. 39
Hashizuma, K., vol. 3, no. 2, p. 15
Henderson, J. B., vol. 1, no. 4, p. 53
Henton, A. C., vol. 1, no. 1, p. 31
Hewitt, G. F., vol. 3, no. 2, p. 21
Ishihara, K., vol. 1, no. 3, p. 23
Jain, S. M., vol. 3, nos. 3-4, p. 99
Jumper, E. J., vol. 2, nos. 3-4, p. 76
Kataya, M., vol. 2, no. 1, p. 28
Klein, R. E., vol. 2, nos. 3-4, p. 76
Korenic, B., vol. 3, nos. 3-4, p. 38
Kulakowski, B. T., vol. 3, nos. 3-4, p. 25
Larson, T. K., vol. 3, no. 2, p. 31
Lehrer, I. H., vol. 2, nos. 3-4, p. 95
Leidenfrost, W., vol. 3, nos. 3-4, p. 38
Levy, S., vol. 1, no. 4, p. 47
Maddox, R. N., vol. 2, nos. 3-4, p. 27
Margittai, T. B., vol. 2, nos. 3-4, p. 40
Mori, S., vol. 2, no. 1, p. 28

progress of the calculations. It may be enlarged, if necessary, by a heat transfer theory which is accepted today as progressive.

Schuster, H. and Stebel, H.

Large-scale trials of a furnace with low NO_x-emission for coal-fired steam generators with liquid ash removal

Brennst.-Wärme-Kraft, vol. 33, no. 11, pp. 443-446, 1981.

This contribution presents the concept of a slag tap furnace with low NO_x-emission, which has been on trial on a power station block of 150 MW. An extensive test program investigated a number of influencing parameters, and proved that the NO_x-emission can be considerably reduced without detrimentally affecting the operational behavior.

Wenz, W.

Operational results of a novel pulverized coal furnace

Brennst.-Wärme-Kraft, vol. 33, no. 11, pp. 447-450, 1981.

In this article, a novel pulverized coal furnace is described which can replace oil or gas fired boiler plants in the central heating range. The fuel used (called "Fluicit") consists of a mixture of brown coal and anthracite. The fuel, its production and the heating plant are described, as well as the results of tests on combustion, storage and transport. The behavior of the fuel "Fluicit" is also considered with respect to SO_2 and NO_x emissions.

Weissenbach, B., and Clausen, J. J.

Thermal storage power station for peak-load generation near consumers

Brennst.-Wärme-Kraft, vol. 33, no. 12, pp. 479-482, 1981.

The thermal storage power station is potentially useful for storing electrical energy in the form of heat. When required, the heat can be transformed into peak-load electricity. The authors describe the principle of this new storage system, the efficiencies obtainable, the exergy flows, and the technical construction of such a plant. In concluding, conventional plants for peak-load supply are compared to the thermal storage power station.

Fiala, W.

Exergetic analysis of various heat accumulators at changing ambient temperatures

Brennst.-Wärme-Kraft, vol. 33, no. 12, pp. 482-486, 1981.

The article includes exergetic analyses of sensible and latent heat accumulators. The results of these analyses may be of special interest if the accumulator temperature lies within the fluctuation range of a periodically changing ambient temperature. By choosing a suitable storage medium, the total exergy requirement for both heating and cooling can be reduced by the addition—with the correct preceding sign—of the released heat (useful heat) and the absorbed heat (useful cold), provided that there are both heating and cooling requirements within one period of ambient temperature fluctuations.

Alefeld, G.

The heat pump transformator, a device for the utilization of "cold district heat"

Brennst.-Wärme-Kraft, vol. 33, no. 12, pp. 486-490, 1981.

The article describes a device which, supplemented to heat pump operation, can be used as a heat transformer, or perform both processes simultaneously. The temperature of the useful heat and its output can be continuously adjusted to the requirement of the consumer. This device thus opens up great opportunities for the utilization of "cold district heat," which is available, for instance, from waste heat of power stations or industrial plants, or in the return piping of district heating nets. As the demand on primary driving energy for this device initially drops at a reducing outside temperature, especially at night, energy savings can be obtained that are far beyond those that can be reached with ordinary heat pumps. The principle of the heat pump transformer and its possible applications are described.

Cumulative Index to Authors

Al-Arabi, M., vol. 3, nos. 3-4, p. 76
Alkidas, A. C., vol. 3, nos. 3-4, p. 66
Baker, C. K., vol. 1, no. 2, p. 28
Bell, K. J., vol. 2, nos. 3-4, p. 27
Berg, J. L., vol. 1, no. 4, p. 21
Berg, W. F., vol. 1, no. 4, p. 21
Boyer, R. C., vol. 2, no. 1, p. 19
Breber, G., vol. 1, no. 2, p. 47
Butterworth, D., vol. 3, nos. 3-4, p. 104
Carnavos, T. C., vol. 1, no. 2, p. 41; vol. 1, no. 4, p. 32
Charaklis, W. G., vol. 3, no. 1, p. 23
Chenoweth, J. M., vol. 2, no. 2, p. 28
Cocks, A. M., vol. 1, no. 1, p. 31
Collier, J. G., vol. 1, no. 3, p. 56
Cooper, A., vol. 1, no. 1, p. 31; vol. 1, no. 3, p. 50
Cozzuol, J. M., vol. 3, no. 2, p. 31
Cuti, F., vol. 3, no. 1, p. 38
Davies, L. M., vol. 1, no. 3, p. 56
Desmond, R. M., vol. 2, no. 1, p. 59
Everly, D., vol. 3, nos. 3-4, p. 60
Gaddis, E. S., vol. 1, no. 1, p. 43
Genetti, W. E., vol. 3, nos. 3-4, p. 60
Gianolio, E., vol. 3, no. 1, p. 38
Graham, R. W., vol. 2, no. 1, p. 39
Hashizuma, K., vol. 3, no. 2, p. 15
Henderson, J. B., vol. 1, no. 4, p. 53
Henton, A. C., vol. 1, no. 1, p. 31
Hewitt, G. F., vol. 3, no. 2, p. 21
Ishihara, K., vol. 1, no. 3, p. 23
Jain, S. M., vol. 3, nos. 3-4, p. 99
Jumper, E. J., vol. 2, nos. 3-4, p. 76
Kataya, M., vol. 2, no. 1, p. 28
Klein, R. E., vol. 2, nos. 3-4, p. 76
Korenic, B., vol. 3, nos. 3-4, p. 38
Kulakowski, B. T., vol. 3, nos. 3-4, p. 25
Larson, T. K., vol. 3, no. 2, p. 31
Lehrer, I. H., vol. 2, nos. 3-4, p. 95
Leidenfrost, W., vol. 3, nos. 3-4, p. 38
Levy, S., vol. 1, no. 4, p. 47
Maddox, R. N., vol. 2, nos. 3-4, p. 27
Margittai, T. B., vol. 2, nos. 3-4, p. 40
Mori, S., vol. 2, no. 1, p. 28

Najjar, M. S., vol. 2, nos. 3–4, p. 27
Nimmons, M. J., vol. 3, no. 1, p. 23
Ortt, J. R., vol. 1, no. 4, p. 38
Osborne, M. W., vol. 1, no. 4, p. 38
Palen, J. W., vol. 1, no. 2, p. 47; vol. 1, no. 3, p. 23
Parker, J. D., vol. 1, no. 4, p. 53
Pase, G. K., vol. 2, no. 1, p. 19
Picologlu, B. F., vol. 3, no. 1, p. 23
Ramdas, V., vol. 1, no. 4, p. 38
Rodriquez, F., vol. 2, no. 2, p. 23
Rubin, F. L., vol. 3, no. 1, p. 49
Sardesai, R. G., vol. 3, nos. 3–4, p. 104
Schlünder, E. U., vol. 1, no. 1, p. 43
Schmidt, F. W., vol. 3, nos. 3–4, p. 25
Shah, M. M., vol. 2, no. 2, p. 51
Shah, R. K., vol. 3, no. 2, p. 49
Shock, R. A. W., vol. 3, nos. 3–4, p. 104
Shukla, K. N., vol. 3, no. 2, p. 62
Singh, K. P., vol. 3, no. 1, p. 19
Small, W. M., vol. 1, no. 2, p. 21
Smyth, R., vol. 2, nos. 3–4, p. 90
Suitor, J. W., vol. 1, no. 3, p. 50
Taborek, J., vol. 1, no. 1, p. 15; vol. 1, no. 2, p. 47; vol. 1, no. 3, p. 23; vol. 2, no. 2, p. 28
Tanimoto, A., vol. 2, no. 2, p. 28
Uhl, V. W., vol. 1, no. 4, p. 38
Usher, J. D., vol. 1, no. 3, p. 50
Veeramani, H., vol. 3, nos. 3–4, p. 99
Walter, G. H., vol. 1, no. 2, p. 28
Webb, R. L., vol. 1, no. 3, p. 33; vol. 2, nos. 3–4, p. 46; vol. 3, nos. 3–4, p. 84
Wiebelt, J. A., vol. 1, no. 4, p. 53
Withers, J. G., vol. 2, no. 1, p. 48; vol. 2, no. 2, p. 43
Yarden, A. L., vol. 2, nos. 3–4, p. 70
Young, R. K., vol. 1, no. 2, p. 21
Zabriskie, J. M., vol. 3, no. 2, p. 31

Cumulative Index to Titles

The accident at Three Mile Island, vol. 1, no. 3, p. 56
Air-side heat transfer in finned tube heat exchangers, vol. 1, no. 3, p. 33
Application of a honeycomb insulator design in a variable high-temperature, high-pressure environment, vol. 3, no. 2, p. 31
Application of dynamic modeling technique to the analysis and prediction of heat transfer with particular reference to agitated vessels, vol. 1, no. 2, p. 28
The cartridge heat exchanger: A new concept for difficult services, vol. 2, nos. 3–4, p. 40
Comment on laboratory models of surface heat loss, vol. 2, no. 1, p. 59
Communication on jacket-side heat transfer, vol. 2, nos. 3–4, p. 95
A comparative assessment of RODbaffle shell-and-tube heat exchangers, vol. 2, nos. 3–4, p. 90
Cooling air in turbulent flow with internally finned tubes, vol. 1, no. 2, p. 41
Cooling water fouling in plate heat exchangers, vol. 1, no. 3, p. 50
Critical review of correlations for predicting two-phase flow pressure drop across tube banks, vol. 1, no. 3, p. 23
The energy-saving nests concept, vol. 2, no. 1, p. 19
An engineering view of wind chill, vol. 2, no. 2, p. 23
Evaporative cooling and heat transfer augmentation related to reduced condenser temperatures, vol. 3, nos. 3–4, p. 38
The evolution of enhanced surface geometries for nucleate boiling, vol. 2, nos. 3–4, p. 46
Evolution of heat exchanger design techniques, vol. 1, no. 1, p. 15
Explicit design of balanced regenerators, vol. 3, nos. 3–4, p. 25
Flow-induced tube vibration data banks for shell-and-tube heat exchangers, vol. 2, no. 2, p. 28
Flow patterns for isothermal condensation in one-pass air-cooled heat exchangers, vol. 1, no. 4, p. 21
Free convection heat transfer from the outside of radial fin tubes, vol. 1, no. 4, p. 53
Fundamental mechanisms that influence the estimate of heat transfer to gas turbine blades, vol. 2, no. 1, p. 39
A general predictive technique for heat transfer during saturated film boiling in tubes, vol. 2, no. 2, p. 51
Heat and mass transfer in multicomponent condensation and boiling, vol. 3, nos. 3–4, p. 104
Heat transfer and pressure drop characteristics of finned tubes in cross flow, vol. 3, no. 2, p. 15
Heat transfer coefficients and pressure drops for air coolers with different numbers of rows under induced and forced draft, vol. 3, no. 1, p. 38
Heat transfer from spiral tubing in an air-fluidized bed, vol. 3, nos. 3–4, p. 60
Heat transfer in a scraped-wall, continuous unit, vol. 1, no. 4, p. 38
Heat transfer performance of internally finned tubes in turbulent flow, vol. 1, no. 4, p. 32
Improved water utilization with plate heat exchangers, vol. 1, no. 1, p. 31
Influence of fouling biofilms on heat transfer, vol. 3, no. 1, p. 23
The influence of improved physical propertty data on calculated heat transfer coefficients, vol. 2, nos. 3–4, p. 27
Large-scale heat transfer research and testing, vol. 2, nos. 3–4, p. 70
Multizone condensers: Desuperheating, condensing, subcooling, vol. 3, no. 1, p. 49
A new look at the old problem of altitude derating of air-cooled high-power broadcast tubes, vol. 2, nos. 3–4, p. 76
On the necessary criteria for stream-symmetric tubular heat exchanger geometries, vol. 3, no. 1, p. 19
Performance, cost effectiveness, and water-side fouling, considerations of enhanced tube heat exchangers for boiling service with tube-side water flow, vol. 3, nos. 3–4, p. 84
Performance of counterflow, parallel plate heat exchangers under laminar flow conditions, vol. 2, no. 1, p. 28
The potential for development in heat exchanger plants, vol. 3, no. 2, p. 21
Prediction of flow regimes in horizontal tube-side condensation, vol. 1, no. 2, p. 47
Research needs in low reynolds number flow heat exchangers, vol. 3, no. 2, p. 49
The RODbaffle heat exchanger, vol. 1, no. 2, p. 21
Specification of process design variables for complex evaporation plants, vol. 3, nos. 3–4, p. 99
Temperature distribution and heat exchange in multipass shell-and-tube exchangers with baffles, vol. 1, no. 1, p. 43
Thermal energy storage for solar power generation: State of the art, vol. 3, no. 2, p. 62
Thermal loading of the cylinder head of a spark-ignition engine, vol. 3, nos. 3–4, p. 66
Three Mile Island: A call for fundamentals and real-time analysis, vol. 1, no. 4, p. 47
Tube-side heat transfer and pressure drop for tubes having helical internal ridging with turbulent/transitional flow of single-phase fluid. Part 1. Single-helix ridging, vol. 2, no. 1, p. 48
Tube-side heat transfer and pressure drop for tubes having helical internal ridging with turbulent/transitional flow of single-phase fluid. Part 2. Multiple-helix ridging, vol. 2, no. 2, p. 43
Turbulent heat transfer in the entrance region of a tube, vol. 3, nos. 3–4, p. 76